

SHIP8, INC.

ATTN: ACCOUNTS PAYABLE
45875 NORTHPORT LOOP EAST
FREMONT, CA 94538
US

AP.SHIP8@SHIP8.COM

PO No.

24030313

PO Date

03/19/2024

Page

1 OF 1

ORDER FROM

101144

PEARCE HEATING & AIR CONDITIONING, INC.
PO BOX 1199
WINTERS, CA 95694
US

SHIP TO

WDC(4000),
SHIP8, INC.
ATTN: CHRISTINE JENKINS
221 HANSON WAY
WOODLAND, CA 95776
US

Buyer

Purchasing Dept

Terms

30 days

FOB

FOB Origin

Ship Via

Best possible

Line No.	Vendor Item No.	Vendor Item Description	Qty Ordered	UOM	Unit Price	Extended Price
1	BLD003-HVAC SN: 18453JSH1V	Provided a professional consultation to determine the customer's needs/concerns and/or solutions.	1.00	Each	125.00	

3-19-24

Total Extended Price =

Job #43355949

Diagnostic Report ([H1] FC_3 sn: SH1V)

Customer Name

Ship 8 Inc.

Technician


Paul A.

Date

2023-10-20

Reason For Call

No heat

Data Plate

Make

Manufacturer of the unit.

Trane

Model/Product Number

Model/Product number of the unit.

GAM5B0A24M21EAA

Serial Number

Serial Number of the unit.

18453JSH1V

Manufactured/Installed Date

Manufactured/Installed date of the unit.

2018

Type of Unit

Type of Unit

Air Handler

Type of Unit: Other



Type of unit if you chose other.

-


Picture of Blower Motor



Picture of Indoor Coil



Picture of Filter



Description of Findings

20A breaker was tripped due to call for emergency heat. Heat strips installed call for a dedicated 40A circuit so when heat strips are engaged breaker will trip. There are no open slots on the panel supplying air handler- client will have an electrician provide them with an option.

Repair Status:

Found no immediate issue with the system.

Customers Expectations

What are the customers expectations of next steps if any are needed

None at this time.

Additional Pictures



Search in mail



- Compose
- Mail
- Inbox 337
- Starred
- Snoozed
- Sent
- Drafts 1
- More

Labels

PO Request for Pearce - WDC - 43355949

Inbox x



James Burford

Christine, Please create a PO for the attached. The diagnostic findings are also in this file. James Burford Regional Facilities



Christine Jenkins

James Is attached PO, 24030313 okay to pay? Christine Jenkins Purchasing Coordinator 550 Northport Parkway Port Wentz



James Burford

to me

Ok to pay.



SHIP8 INC.

James Burford
Regional Facilities Director
311 International Trade Pkwy
Port Wentworth, GA 31407

C:912.507.7681

- Ok to pay.
- Yes, approved.
- Yes, thank you.

- Reply
- Forward



Pearce Heating & Air Conditioning, Inc.
 PO BOX 1199, Winters, CA 95694 United States
 (530) 795-4300

BILL TO

Ship 8 Inc.
 2222 East Beamer Street
 Woodland, CA 95776 USA

INVOICE 43355949	INVOICE DATE Oct 20, 2023
----------------------------	-------------------------------------

JOB ADDRESS

Ship 8 Inc.
 2222 East Beamer Street
 Woodland, CA 95776 USA

Completed Date: 10/20/2023
Payment Term: Due Upon Receipt
Due Date: 10/20/2023

TASK	DESCRIPTION	QTY	PRICE	TOTAL
Commercial Diagnostic	Provided a professional consultation to determine the customer's needs/concerns and/or solutions.	1.00	\$125.00	\$125.00
TRANE GAM5B0A24M21EAA S/N: 18453JSH1V				
Air Handler Info	Air Handler's Info	1.00	\$0.00	\$0.00
TRANE GAM5B0A24M21EAA S/N: 18453JSH1V				

POTENTIAL SAVINGS	\$0.00
SUB-TOTAL	\$125.00
TAX	\$0.00
TOTAL DUE	\$125.00
BALANCE DUE	\$125.00

Thank you for choosing Pearce Heating & Air Conditioning, Inc.

This invoice is agreed and acknowledged. Payment is due upon receipt. A service fee will be charged for any returned checks, and a financing charge of 1% per month shall be applied for overdue amounts.