

**SHIP8, INC.**

ATTN: ACCOUNTS PAYABLE  
45875 NORTHPORT LOOP EAST  
FREMONT, CA 94538

US  
AP.SHIP8@SHIP8.COM

**ORDER FROM**

1030

CISCO AIR SYSTEMS, INC.  
214 - 27TH STREET  
SACRAMENTO, CA 95816-3201

**SHIP TO**

WDC(4000),  
SHIP8, INC.  
ATTN: CHRISTINE JENKINS  
221 HANSON WAY  
WOODLAND, CA 95776  
US

**PO No.**

24040391

**PO Date**

04/08/2024

**Page**

1 OF 1

**Buyer**

Purchasing Dept

**Terms**

Net 30 Days

**FOB**

FOB Origin

**Ship Via**

Best possible

Line No.	Vendor Item No.	Vendor Item Description	Qty Ordered	UOM	Unit Price	Extended Price
1	Compressor PM	Perform Minor PM Service	1.00	Each	1,961.00	

*JWV. 4-11-24*

**Total Extended Price =**



**NOTES / INSTRUCTIONS (Not part of printed form)**

Please select and thoroughly review the below linked  
**Warehouse Purchases and Approval Policy - Mar 2023**

This form is required for all SHIP8 INC. purchase requests

Fill out form in its entirety  
Confirm pricing with the vendor  
Obtain all appropriate approvals

Download/Save completed form as a pdf (include quote if applicable)  
Email PDF to AP.SHIP8@SHIP8.com

Upload a copy of the signed PDF to the Purchase Req Forms  
folder on the Google Drive to relevant location

Once product is received, upload POD to the shared drive

so that payment to the vendor can be processed

S:\POD Public File



214 27th Street  
Sacramento, CA 95816

SIGNOFF	
SIGNOFF DATE	PO Number
4/11/2024 3:59 PM	24040391
Customer Number	Job Number
6164	3429290

**BILL TO:**

SHIP8 INC\*  
45875 Northport Loop East  
Fremont, CA 94538

**SHIP TO:**

SHIP8 INC\*  
221 Hanson Way  
Woodland, CA 95776

**Parts**

	Quantity	Part #	Description	Equipment
1	1	6.1938.0 - KEL	FILTER MAT	BS61 (1030)
2	1	619810 - KEL	KAE OIL ELEMENT	BS61 (1030)
3	1	620840 - KEL	KAE AIR ELEMENT	BS61 (1030)
4	1	LSK - UCI	OIL SAMPLE	BS61 (1030)

**Signature**

Edward Vega



**WORK ORDER INSPECTION SHEET**

24 HR. EMERGENCY SERVICE

TOLL FREE 800-813-6763



CL # 479665

Date of Inspection	2024-04-11	Unit I.D.		<input type="checkbox"/> Service Plan
Customer Name	SHIP8 INC*	Model No.	BS61	<input checked="" type="checkbox"/> Service Call
Location	221 Hanson Way Woodland, CA 95776	Serial No.	1030	<input type="checkbox"/> Start Up
Customer Contact	Edward Vega	W.O. #	SR3429290	<input type="checkbox"/> Warranty P.O.
		P.O. #	24040391	

GENERAL INSPECTIONS (Chk & Record, If Applicable)				ITEMS SPECIFIC TO OIL FREE ROTARY COMPRESSORS								
OK	Replaced / Cleaned / Rebuilt During Visit			OK	Replaced / Cleaned / Rebuilt During Visit							
	Still Requires Repair / Changing / Cleaning				Still Requires Repair / Changing / Cleaning							
1	<input checked="" type="checkbox"/>	Fill Out Orange Card - Replace if necessary		39		1st Stage Disch. Temp. (Full Load)	X					
2	<input checked="" type="checkbox"/>	Run Hrs. 26382	Load Hrs. 6636	40		I/C Press. Loaded	X					
3	<input checked="" type="checkbox"/>	Hours on Coolant	490	41		Oil Pressure	X					
4	<input checked="" type="checkbox"/>	Target or Load/Unload Pressure	100-110	42		2nd Stage Inlet Temp.	X					
5		Auto Stop	<input checked="" type="checkbox"/>	43		2nd Stage Disch. Temp.	X					
6	<input checked="" type="checkbox"/>	Full Load Airend Discharge Temp.	185°	44		Unloaded Inlet Vacuum	X					
7	<input checked="" type="checkbox"/>	Full Load Coolant Injection Temp.	169°	45		Inspect/Clean Gearcase Breather	X					
8	<input checked="" type="checkbox"/>	Full Load Pkg. Discharge Temp.	85°	<b>ROTARY ELECTRICAL INSPECTION</b> (Chk & Record the Following)								
9	<input checked="" type="checkbox"/>	Room Ambient Temp.	80°									
10	<input checked="" type="checkbox"/>	Thermostatic Control Valve Temp.	Open°	46	Voltage @ Full Load	A 475	B 475	C 475	D 475			
11		Watercooled O/C	IN X OUT X	47	Mot A. @ F.T.	T1/U 60	T2/V 60	T3/W 59				
12		Watercooled A/C	IN X OUT X	48	DOL A. @ F.L.	L1 X	L2 X	L3 X				
13		Unloaded Sump PSI	X	49	Pkg A. @ F.L.	L1 62	L2 61	L3 62				
14		Full Load Separator Pressure Drop	X	50	Fan Motor Amp	T1/U X	T2/V X	T3/W X				
15	<input checked="" type="checkbox"/>	Coolant Filter D/P	New	51	<b>MOTOR DATA</b>	H.P. 50	RPM 1780	S.F. 1.15				
16	<input checked="" type="checkbox"/>	Coolant Type	Cs46	52	Frame	Ip55	V 460	M.A. 64				
17	<input checked="" type="checkbox"/>	Coolant Sample Taken	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	53	O.L. Setting	42	O.L. Fan X	F.A. X				
18		Acid Test Performed	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	54	<input checked="" type="checkbox"/>	Inspect Contactors						
19	<input checked="" type="checkbox"/>	Check Coolant Level		55	<input checked="" type="checkbox"/>	Ck Electrical Conn.						
20	<input checked="" type="checkbox"/>	Inspect for Coolant Leaks		56	<input checked="" type="checkbox"/>	Control Voltage	1	2	3			
21	<input checked="" type="checkbox"/>	Inspect for Air Leaks		<b>NIRVANA ELECTRICAL INSPECTIONS (Chk &amp; Record the Following)</b>								
22	<input checked="" type="checkbox"/>	Safety Valve Installed / Operational										
23	<input checked="" type="checkbox"/>	Inspect Discharge C.V. / MPV		57		Package Kw	X					
24	<input checked="" type="checkbox"/>	Inspect Blowdown Valve		58		Motor Speed (Max)	X					
25	<input checked="" type="checkbox"/>	Coupling / Belts Condition		59		Motor V. (Max Speed & Target P.)	X					
26	<input checked="" type="checkbox"/>	Inspect All Hoses		60		Motor A. (Max Speed & Target P.)	X					
27		Inspect OWS		61		DC Bus Voltage (Full Load)	X					
28	<input checked="" type="checkbox"/>	Inspect Coalescing / Particulate Filters		62		Rotor Clearance	X					
29	<input checked="" type="checkbox"/>	Inspect / Clean All Air Cooled Coolers		63		Inspect Hall Effect Sensors	X					
30	<input checked="" type="checkbox"/>	Inspect / Clean Condensate Drains		<b>SHOCK PULSE READINGS - SPM</b>								
31	<input checked="" type="checkbox"/>	Inspect / Clean Main / Blower Motors										
32		Grease Main / Fan Motor		(1 Stage)		(2 Stage)		MOT				
33	<input checked="" type="checkbox"/>	Inspect and Clean Scav. Orif / Screen		mr1	mr2	bg	lpm1	lpm2	hpm1	hpm2	DE	ODE
34	<input checked="" type="checkbox"/>	Inlet Filter Condition										
35	<input checked="" type="checkbox"/>	PDM Filter Condition										
36		Dryer Drain Clean		Reset Service Timer	yes	no	PO #					
37		Dryer Condenser Clean		Returned Part	yes	no	X	Tech Name	Matt Citrino			
38		Dew Point										

Return Location:

**COMMENTS**

Minor pm

Test ran, took electrical and temp readings.

Blew out cooler and inside unit.

No issues found



REMIT TO: 214 27th Street  
Sacramento, CA 95816  
p. (800) 813-6763

Invoice	
Invoice Date 4/12/2024	Number Invoice 264826-1
Customer Number 6164	Due Date 5/12/2024

**SOLD TO:**  
SHIP8 INC\*  
45875 Northport Loop East  
Fremont, CA 94538

**SHIP TO:**  
SHIP8 INC\*  
221 Hanson Way  
Woodland, CA 95776

PO Number	Order Date	Salesperson	Job Number
24040391	4/11/2024	Will Jenkins	SR3429290

**Terms**  
Net 30

Mfg	Model	Serial #	Description
KAESER	BS61	1030	50 HP COMPRESSOR

Description	Subtotal	Tax	Total
Total Parts	496.91	39.75	536.66
Total Labor	1,425.00	0.00	1,425.00

---

<b>Totals</b>	1,921.91	39.75	1,961.66
---------------	----------	-------	----------

---

<b>Total Due</b>			1,961.66
------------------	--	--	----------