

**SHIP8, INC.**

ATTN: ACCOUNTS PAYABLE  
 45875 NORTHPORT LOOP EAST  
 FREMONT, CA 94538

US

AP.SHIP8@SHIP8.COM

**ORDER FROM**

1069

LIFT POWER INC.

JACKSONVILLE, FL 32254

**SHIP TO**

SD2(2000),  
 SHIP8, INC.  
 ATTN: CHRISTINE JENKINS  
 550 NORTHPORT PARKWAY  
 PORT WENTWORTH, GA 31407  
 US

Ship Via

Best possible

FOB

FOB Destination

Terms

Net 30 Days

Buyer

Purchasing Dept

Extended Price

Unit Price

UOM

Qty Ordered

Vendor Item Description

Vendor Item No.

Line No.

Line No.	Vendor Item No.	Vendor Item Description	Qty Ordered	UOM	Unit Price	Extended Price
1	BLD009 - DOCK DOORS	DOORS 9x10	120.00	Each	30.00	3600.00
2	BLD009 - DOCK DOORS	DOORS 12x14	4.00	Each	45.00	180.00
3	MSCNOTES	6x8 mechanical	104.00	Each	40.00	4160.00
4	MSCNOTES	Restraints	32.00	Each	20.00	640.00
5	MSCNOTES	EOD	16.00	Each	20.00	320.00

**Total Extended Price =**

Re: Invoice 37700334 from Lift Power Inc

James Burford  
To: Christine Jenkins

Approved to pay.



**SHIP8 INC**

James Burford  
Regional Facilities Director  
311 International Trade Pkwy  
Port Wentworth, GA 31407

C:912.507.7881

Handwritten signature: *James Burford*

# LIFTPOWER

Industrial Trucks • Materials Handling Equipment  
 6801 Suemac Place  
 Jacksonville, FL 32254  
 (904) 788-0250 | Fax (904) 781-1451

Inv # 377000334

Inv Date 7/8/2024

Terms - Net 30

## Dock and Door PM Invoice

Salesman:

Writer:

**BILL**

TO: 7253  
 SHIP8 INC  
 45875 NORTHPORT LOOP EAST  
 Fremont, CA 94538  
 510-490-9788

**SHIP**

TO: 7256  
 SHIP8 INC  
 SD2  
 550 NORTHPORT PKWY  
 Savannah, GA 31407  
 510-490-9788

Arrived on site checked in and got to dock and door 146 to resume pms and added tension to Doors 146,145,141. No fault found at positions 133,132,131,129,126,125,124,122. Put in a quote for new lip cylinder on Deck 127. Added tension to levelers 141,130,121 also had to get top-right roller back in on door 123. pms complete.  
 Travis Brantley (2024-07-05)  
 Gary Miller (2024-07-05)  
 Sam Foote (2024-07-05)

Part #	Whse	Description	Bin	Qty	BO	Shipped	Each	Extended
255	DV1228	Bracket, Top Adjustable, 12ga	L5-C	2	0	2	10.00	20.00
R2-9	DV1228	Roller, 2", 9" stem	L4-F	2	0	2	10.00	20.00
363145-001	DV1228	DOCK / DOOR LUBE CAN	L3-D	24	0	24	15.00	360.00
363004-001	DV1228	GREASE JT6 HIGH TEMP 14OZ	L3-C	19	0	19	15.00	285.00
Labor								8,900.00

Need to place a service call?

Please visit our website [www.liftpower.com](http://www.liftpower.com), click on service request, fill out the form and click submit. The next available service technician will be dispatched to you.

Invoices sent to collections will be subject to additional costs associated with collection of a debt over and above the original debt amount.

Sub Total	\$9,585.00
Tax	\$0.00
Total	\$9,585.00

# LIFTPOWER

Industrial Trucks • Materials Handling Equipment  
6801 Suemac Place  
Jacksonville, FL 32254  
(904) 783-0250 | Fax (904) 781-1451

Inv # 377000334

Inv Date 7/8/2024

Terms - Net 30

## Dock and Door PM Invoice

Salesman:

Writer:

### BILL

TO: 7253  
SHIP8 INC  
45875 NORTHPORT LOOP EAST  
Fremont, GA 94538  
510-490-9788

### SHIP

TO: 7256  
SHIP8 INC  
SD2  
550 NORTHPORT PKWY  
Savannah, GA 31407  
510-490-9788

PO #	Ship Via	FOB	PM Due Date	Make	Model	Serial #	Unit #	Meter
2023 PO: B23060558			6/12/2024	DDPM	DDPM	7256SHIP8_120D4RD104L32R16EOD		0

ANNUAL PM SERVICE. CONTACT: JAMES BURFORD 912-507-7881  
MUST BILL LUBE AND PARTS SEPERATELY

Scope of Work:  
(120) 9x10' Doors  
(4) 12x14' Ramp Doors  
(104) 6x8' Levelers  
(32) Restraints  
(16) EODs

#### WORK PERFORMED:

Arrived on site checked in and got to ramp door 300 to start pm maintenance on all docks and doors. (NEF) No Fault Found at positions 305,307,309,310,311,313,316,317,319,321,325,328,331,333. Doors that need tension 329,330,334. Door 327 was backed into and all 5 panels are damaged put in quote for 5 new panels. Door 304 was missing its rope so added rope. And door 322 blocked.

Travis Brantley (2024-06-24)  
Gary Miller (2024-06-24)

Arrived on site checked in and got to door 336 to resume pms and No fault found at positions 336,339,340,341,342,343,345,346,347,348,351,352,353,355,358. Doors that needs tension 357,333. Docks blocked 349,354,359.  
Travis Brantley (2024-06-25)

Arrived on site checked in and got to dock and door 360 to resume pms. Docks and doors with No Fault Found 365,390,392,393,398,399,400,403,406,413,414,415,191,189,188,185,181,168,166,165,164,163. Positions blocked 177,179,183,388,386,384,378,360. Positions that need tension 361,363,364,366,376,378,380,381,382,384,385,387,389,391,394,397,404,405. Put in a quote for Position 402 for a new bottom panel and intermediate panel. Door 401 needs cone adjustment.  
Travis Brantley (2024-06-26)

Arrived on site checked in and got to dock and door 161 to resume pms. Docks and doors with No Fault Found are 161,159,158,157,155,154,152,151,149,147,143,139,137,135,134,119. Docks blocked 146,145,133,132,131,130,129,127,126,125,124,123,122,120. Doors added tension to 329,330,333,334,357,361,363,354,366. Dock 141 added tension to. Got with Patrick with list of blocked positions.  
Travis Brantley (2024-06-27)

Arrived on site checked in and got to door 376 to resume pms and added tension on doors 376,378,380,381,382,384,385,387,388,389,391,394,404,405. Added 2 new top brackets and rollers on door 177 also bent track and door bumper back straight. Dock and door 397 conveyor broken down and blocking leveler and can't test and door needs tension was told to skip by Curtis 401 same problem with conveyor in the way.  
Travis Brantley (2024-06-28)