

**SHIP8, INC.**

ATTN: ACCOUNTS PAYABLE  
45875 NORTHPORT LOOP EAST  
FREMONT, CA 94538  
US  
AP.SHIP8@SHIP8.COM

**ORDER FROM**

100248

CHAMPION FIRE PROTECTON, INC.

SAVANNAH, GA 31401

**SHIP TO**

SD2(2000),  
SHIP8, INC.  
ATTN: CHRISTINE JENKINS  
550 NORTHPORT PARKWAY  
PORT WENTWORTH, GA 31407  
US

PO No.

24121431

PO Date

12/13/2024

Page

1 OF 1

Buyer

Terms

FOB

Ship Via

Purchasing Dept

Net 30 Days

FOB Origin

Best possible

Vendor Item Description

Qty Ordered

UOM

Unit Price

Extended Price

1

NA

NTE \$540.00

1.00

Each

*JM 3/18*

540.00

Total Extended Price =

open PO 24121431

 Outlook

---

**Re: Fire panel issues**

---

**From** Patrick Andreshack <patrick.andreshack@ship8.com>

**Date** Thu 12/12/2024 5:42 PM

**To** Charles Wood <cwood@championfp.com>; Terry Turner <tturner@championfp.com>

**Cc** James Burford <james.burford@ship8.com>; Christine Jenkins <christine.jenkins@ship8.com>; Branden Washington <branden.washington@ship8.com>

Christine,

Please create a PO for champion fire. Please make it for NTE \$540.00. Thank you



**SHIP8 INC.**

Patrick Andreshak  
Maintenance Manager  
550 Northport Parkway  
Port Wentworth, GA, 31407

**C:** 912.414.6118

---

**From:** Patrick Andreshack <patrick.andreshack@ship8.com>

**Sent:** Thursday, December 12, 2024 2:19:51 PM

**To:** Charles Wood <cwood@championfp.com>; Terry Turner <tturner@championfp.com>

**Cc:** James Burford <james.burford@ship8.com>; Christine Jenkins <christine.jenkins@ship8.com>; Branden Washington <branden.washington@ship8.com>

**Subject:** Re: Fire panel issues

That will work. Please send



**SHIP8 INC.**

Patrick Andreshak

Maintenance Manager  
550 Northport Parkway  
Port Wentworth , GA , 31407

C: 912.414.6118

---


**From:** Charles Wood <cwood@championfp.com>  
**Sent:** Thursday, December 12, 2024 1:32:55 PM  
**To:** Patrick Andreshack <patrick.andreshack@ship8.com>; Terry Turner <tturner@championfp.com>  
**Cc:** James Burford <james.burford@ship8.com>; Christine Jenkins <christine.jenkins@ship8.com>; Branden Washington <branden.washington@ship8.com>  
**Subject:** RE: Fire panel issues

Patrick,

I can give you a NTE quote of \$540.00. That will be for 4 hours of labor to trouble shoot. If additional time or parts is needed, I would have to quote that separately.

Thanks,

Charles Wood, ET, GROL  
Fire Alarm Service Manager  
Champion Fire Protection, Inc  
O-912-234-0111  
C-912-663-8279



133262


0029785060

---

**From:** Patrick Andreshack <patrick.andreshack@ship8.com>  
**Sent:** Thursday, December 12, 2024 11:58 AM  
**To:** Charles Wood <cwood@championfp.com>; Terry Turner <tturner@championfp.com>  
**Cc:** James Burford <james.burford@ship8.com>; Christine Jenkins <christine.jenkins@ship8.com>; Branden Washington <branden.washington@ship8.com>  
**Subject:** Re: Fire panel issues

Champion,

Still having these same issues with the Panel at our 550 Location. Please send a quote for a service Tech to come and take a look. Thank you



**SHIP8 INC.**

Patrick Andreshak  
Maintenance Manager  
550 Northport Parkway  
Port Wentworth, GA 31407

C:912.414.6118

---

**From:** Charles Wood <[cwood@championfp.com](mailto:cwood@championfp.com)>  
**Sent:** Thursday, November 14, 2024 8:29 AM  
**To:** Patrick Andreshak <[patrick.andreshack@ship8.com](mailto:patrick.andreshack@ship8.com)>; Terry Turner <[tturner@championfp.com](mailto:tturner@championfp.com)>  
**Subject:** Re: Fire panel issues

That looks like a breaker has been turned off for the exhaust fans.

Charles Wood, ET, GROL  
Fire Alarm Service Manager  
Champion Fire Protection, Inc  
O-912-234-0111  
C-912-663-8279  
NICET ID 133262

---

**From:** Patrick Andreshak <[patrick.andreshack@ship8.com](mailto:patrick.andreshack@ship8.com)>  
**Sent:** Thursday, November 14, 2024 8:28:00 AM  
**To:** Charles Wood <[cwood@championfp.com](mailto:cwood@championfp.com)>; Terry Turner <[tturner@championfp.com](mailto:tturner@championfp.com)>  
**Subject:** Re: Fire panel issues

Charles,  
Now it is showing another alarm on the panel.  
Please advise.



**SHIP8 INC.**

Patrick Andreshak  
Maintenance Manager  
550 Northport Parkway  
Port Wentworth, GA, 31407

C: 912.414.6118

**From:** Patrick Andreshack <patrick.andreshack@ship8.com>  
**Sent:** Wednesday, November 13, 2024 7:55:57 PM  
**To:** Charles Wood <cwood@championfp.com>; Terry Turner <tturner@championfp.com>  
**Subject:** Re: Fire panel issues

Charles,

Thank you , I will try that in the morning



**SHIP8 INC.**

Patrick Andreshak  
Maintenance Manager  
550 Northport Parkway  
Port Wentworth , GA , 31407

C: 912.414.6118

---

**From:** Charles Wood <cwood@championfp.com>  
**Sent:** Wednesday, November 13, 2024 7:53 PM  
**To:** Patrick Andreshack <patrick.andreshack@ship8.com>; Terry Turner <tturner@championfp.com>  
**Subject:** Re: Fire panel issues

If you are on-site, press the enter button. It will ask for the password. The password is 2222. It will ask if you want to accept the map. Hit enter again and it should clear.

Charles Wood, ET, GROL  
Fire Alarm Service Manager  
Champion Fire Protection, Inc  
O-912-234-0111  
C-912-663-8279  
NICET ID 133262

---

**From:** Patrick Andreshack <patrick.andreshack@ship8.com>  
**Sent:** Wednesday, November 13, 2024 7:37:11 PM  
**To:** Terry Turner <tturner@championfp.com>; Charles Wood <cwood@championfp.com>  
**Subject:** Fire panel issues

Champion,

Please let me know what this issue means on this panel. This is at our 550 location. Thank you

**Re: Fire panel issues**

---

**From** Patrick Andreshack <patrick.andreshack@ship8.com>

**Date** Tue 3/18/2025 11:20 AM

**To** Christine Jenkins <christine.jenkins@ship8.com>; Charles Wood <cwood@championfp.com>; Terry Turner <tturner@championfp.com>

**Cc** James Burford <james.burford@ship8.com>; Branden Washington <branden.washington@ship8.com>

completed



**SHIP8 INC.**

Patrick Andreshak  
Maintenance Manager  
550 Northport Parkway  
Port Wentworth, GA 31407

C:912.414.6118

---

**From:** Christine Jenkins <christine.jenkins@ship8.com>

**Sent:** Tuesday, March 18, 2025 7:53 AM

**To:** Patrick Andreshack <patrick.andreshack@ship8.com>; Charles Wood <cwood@championfp.com>; Terry Turner <tturner@championfp.com>

**Cc:** James Burford <james.burford@ship8.com>; Branden Washington <branden.washington@ship8.com>

**Subject:** Re: Fire panel issues

**Team**

**Has PO 24121431 been completed?**



**SHIP8 INC.**

Champion Fire Protection, Inc.  
 825 Wheaton Street  
 Savannah, GA 31401  
 Phone: (912) 234-0111  
 Fax: (912) 236-1303

**INVOICE**

INVOICE NO  
 136637

CUST SHIP8 INC  
 45875 NORTHPORT LOOP E  
 FREMONT, CA 94538

SITE 550 NORTHPORT PKWY  
 SHIP8, INC  
 SAVANNAH, GA 31407

ACCOUNT NO	PO NUMBER	INVOICE DATE	TERMS	DUE DATE	PAGE
193342	PO24121431	3/14/2025	Net 30	4/13/2025	1

DATE COMPLETED: 12/17/24  
 FIRE ALARM SERVICE

Upon arrival located the breaker for the fan shutdown. Found breaker was off and turned it back on.  
 Fan shutdown trouble cleared. All systems normal upon completion.

QUANTITY	DESCRIPTION	UNIT PRICE	EXTENDED
1	FIRE ALARM LABOR	270.0000	270.00 *

\* means item is non-taxable

**TOTAL AMOUNT 270.00**

**Champion Fire is paperless!**  
**If you would like your invoices emailed**  
**send request to: [ar@championfp.com](mailto:ar@championfp.com)**

**To request inspection reports please**  
**email: [swood@championfp.com](mailto:swood@championfp.com)**

**If you would like to be emailed a credit**  
**card payment link send request to:**  
**"[ar@championfp.com](mailto:ar@championfp.com)" with your**  
**invoice number. (Invoices over \$1500 are**  
**subject to a 3% processing fee)**