



## ANNUAL FIRE ALARM REPORT

DATE: 1/22/2026  
 CUSTOMER: OA LOGISTICS  
 ADDRESS: 1680 TIDE CT, WOODLAND CA  
 CONTACT: ALEX GONZELEZ

PANEL: ADEMCO VISTA 124 FA  
 DIALER: UDACT  
 TECHNICIAN: TRAVIS GILL  
 PHONE: 916-873-1791

### DEVICES

ADDRESS	FLOOR	DEVICE TYPE	DESCRIPTION	PASS	FAIL	COMMENTS
10	1ST	OS&Y	SOUTHWEST OS&Y	N/A		COULD NOT LOCATE
11	1ST	TAMPER	PUMP HOUSE TAMPER	X		A016-2055
12	1ST	SMOKE	ELECTRIC ROOM SMOKE	X		008-0013
13	1ST	TAMPER	TAMPER PUMP HOUSE 13	X		A010-6117
14	1ST	WATERFLOW	RISER 12 WATERFLOW	X		A086303
15	1ST	WATERFLOW	RISER 11 WATERFLOW	X		A096031
16	1ST	TAMPER	RISER TAMPER 11	X		A010-3607
17	1ST	TAMPER	RISER TAMPER 3	X		A0128039
18	1ST	WATERFLOW	RISER 10 WATERFLOW	X		A0152591
19	1ST	WATERFLOW	RISER 9 WATERFLOW	X		A097623
20	1ST	TAMPER	RISER TAMPER 9	X		A083517
21	1ST	TAMPER	RISER TAMPER 12	X		A1031293
22	1ST	TAMPER	RISER TAMPER 7	X		A0105925
24	1ST	WATERFLOW	RISER 8 WATERFLOW	X		A014-8543
<b>23</b>	<b>1ST</b>	<b>WATERFLOW</b>	<b>RISER 7 WATERFLOW</b>		<b>X</b>	<b>DID NOT REPORT</b>
25	1ST	TAMPER	RISER TAMPER 8	X		A0089223
26	1ST	TAMPER	RISER TAMPER 1	X		A098127
27	1ST	WATERFLOW	RISER 1 WATERFLOW	X		A096679
28	1ST	WATERFLOW	RISER 2 WATERFLOW	X		A0153045
29	1ST	TAMPER	RISER TAMPER 2	X		A0239877
30	1ST	TAMPER	RISER TAMPER 1	X		A097-5989
31	1ST	WATERFLOW	RISER 3 WATERFLOW	X		A0066997
32	1ST	WATERFLOW	RISER 4 WATERFLOW	X		A098317
33	1ST	TAMPER	RISER 4 TAMPER	X		A0245895
<b>34</b>	<b>1ST</b>	<b>TAMPER</b>	<b>RISER 5 TAMPER</b>		<b>X</b>	<b>DID NOT REPORT A1031117?</b>
35	1ST	WATERFLOW	RISER 5 WATERFLOW	X		A0118165
36	1ST	WATERFLOW	RISER 6 WATERFLOW	X		A076463
37	1ST	TAMPER	RISER 6 TAMPER	X		A0142583
38	1ST	SUPERVISORY	FIRE PUMP OFF	X		A068967
39	1ST	SUPERVISORY	FIRE PUMP TROUBLE	X		A098127
1	1ST	PULL STATION	PULL STATION ELECTRIC ROOM	X		ON FACP ZONE 1
61	1ST	SUPERVISORY	FIRE PUMP RUNNING	X		A099-1061
41	1ST	TAMPER	PUMP HOUSE BUTTERFLY 4	X		A079703
42	1ST	TAMPER	PUMP HOUSE BUTTERFLY 5	X		A0162055
43	1ST	TAMPER	PUMP HOUSE BUTTERFLY 6	X		A0137918
44	1ST	OS&Y	PUMP HOUSE OS&Y	X		A0460535
51	1ST	PIV	BEHIND PUMP HOUSE	X		A316861
49	1ST	OS&Y	MAIN ENTRANCE STREET OS&Y	X		A090735
45	1ST	WATERFLOW	PUMP ROOM WATERFLOW	X		A006-0501







